



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 03/09/2026

Area: CHP

Equipment	Job
CC 14,25, 28,109	Motor vibration readings measured
CC 17	PC kept in ckt
CCR Processor panel	Cable dressing done
SCR 2	Cabin top 200W fixture replaced
SCR 8	8 nos 35W LED fixtures provided and improved lighting
CC 19,22, 33,34,S 3,SCR 2	PPM was done
CC 36	Motor power cable damaged pipe removed , new pipe welded , laid the cable and terminated
CC 52,53,113,113A	PPM was done