



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/06/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	TRIPPED ON OLR	RESET DONE	08:40:00	08:50:00	
2	OHP	TBS ON CO23	BC NOT RUNNING/OLR ACTED AND BC,ZSS WAS BYPASSED	RESET DONE AND ZSS KEPT IN CKT	11:40:00	12:10:00	
3	CHP	SCR 1 ON CC31	LUFFING NOT TAKING PLACE/OLR ACTED DUE TO OIL LEVEL LOW	RESET DONE AFTER FILL THE OIL	07:05:00	07:55:00	
4	CHP	CC 54	TRIPPED ON OLR	RESET DONE	07:30:00	07:40:00	
5	CHP	CC 125	TRIPPED ON OLR	RESET DONE	09:00:00	09:05:00	
6	CHP	CC 14	ZSS ACTING/CAGE STUCKUPWITH MATERIAL	ZSS CAGE MADE FREE	12:50:00	13:00:00	
7	WT	AF 5	DRIVE PROBLEM PENDING FROM C SHIFT	DRIVE REPLACED AND TESTED THEN GIVEN CLEARENCE	06:00:00	10:00:00	DELTA DRIVE INSTALED