



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/06/2026

Incharge(s): G Eswara Rao

Shift: A

| Sl No | Area | Equipment      | Problem                                                            | Action                                                | From     | To       | Remarks          |
|-------|------|----------------|--------------------------------------------------------------------|-------------------------------------------------------|----------|----------|------------------|
| 1     | OHP  | CO 26          | TRIPPED ON OLR                                                     | RESET DONE                                            | 06:05:00 | 06:10:00 |                  |
| 2     | OHP  | WOBR ON CO 29  | LUFFING NOT TAKING PLACE OLR ACTED                                 | RESET DONE                                            | 11:45:00 | 11:50:00 |                  |
| 3     | CHP  | CC 27          | REPORTED /MCCB TRIPPED DUE TO 2 LUGS GOT BURNT AT PLNEL OUT GOING. | LUGS AND FINGER CONTACTS REPLACED AND GIVEN CLEARENCE | 07:20:00 | 11:00:00 |                  |
| 4     | CHP  | CC 28          | TRIPPED ON OLR                                                     | RESET DONE                                            | 09:30:00 | 09:40:00 |                  |
| 5     | CHP  | CC 201         | TRIPPED ON OLR                                                     | RESET DONE                                            | 06:45:00 | 06:55:00 |                  |
| 6     | CHP  | SCR 2 ON CC33  | PCRD FAST ACTED                                                    | RESET DONE                                            | 09:10:00 | 09:15:00 |                  |
| 7     | CHP  | SCRC 2 ONCC 33 | BC NOT RUNNING/OLR ACTED                                           | RESET DONE                                            | 12:35:00 | 12:45:00 |                  |
| 8     | CHP  | SCR 3 ON CC37  | BW NOT RUNNING/                                                    | PUMP ON COMMAND GIVEN THEN OK                         | 10:15:00 | 10:25:00 | WRONG C OMPLAINT |