



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/05/2026

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR-3	PUMP 2 ESTOP NOT RELEASING PROPERLY	CLEANED AND TESTED	18:00:00	18:20:00	
2	OHP	VS-1A	TRIPPED ON OL 3 TIMES	RESET DONE	17:20:00 19:15:00 21:10:00	17:30:00 19:25:00 21:20:00	SCREEN BEARING TEMP HIGH 64 MOTOR TEMP NORMAL
3	CHP	CC-39 SCR-7	BC NOT RUNNING	30 DEGREE LIMIT ACTED ... CLEANED AND RESET	16:55:00	17:15:00	
4	CHP	CC-46	TRIPPED MCCB	RESET DONE AND CHECKED FOUND OK	17:55:00	18:05:00	
5	CHP	CC-125	TRIPPED ON OL	RESET DONE	20:30:00	20:35:00	
6	CHP	CC-44	TRIPPED ON OL	RESET	20:40:00 20:55:00	20:45:00 21:00:00	