



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/05/2026

Area: CHP

Equipment	Job
JH C 3	2 nos 200W LED fixtures provided
CC 26	BS ckt rectification job under progress
CC 20	Running inspection defect rectified
LC 18	Rooms cleaning done
JH C 211	Sump pump motor connection given and trail run was taken
CC 36,S 1	End limit striker re welded and tested
SCR 2	PLC panel maintenance was done
R 1	All drives PPM was done
CC 116,117	Cable tray cleaning under progress