



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/05/2026

Area: CHP

Equipment	Job
CC 58TT	Position sensor replaced and kept in ckt
CM 27,28	Roof and inside rooms cleaning done
LC 14,15,CM 9,16	7 nos tube lamps replaced
CC 106,213	HT coupler heating element provided
CC 222/223 tunnel	Tail end lighting improved
SCR 2	PCRD chain snap detection sensor kept in ckt and tested
CC 34,38	Interlock cage modification done
SCR 5	MCC bus bar maintenance was done
CC 36,R 1,CC 37,SCR 3,CC 39,SCR 7	Running inspection was done
Coal complex	Rooms cleaning done
CC 15,19,22,46,47,50	PPM was done