



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 18/06/2026

Area: WT

Equipment	Job
OT-4 SERIES	MOTOR AND PANEL SIDE PPM DONE
CP-4	ISOLATOR INSPECTION DONE
OT-4	HYDRAULIC PUMP COUPLING CHANGED AND TESTED