



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 03/08/2026

Area: OHP

Equipment	Job
jh-14,(2), bpc-1,bpc-2, 27a hoists	ppm is done.
jh-14,(2), bpc-1,bpc-2, 27a hoists	ppm is done.
co-32,22 gallery focus, co-25 road focus lamps	lighting improved.
co-32,22 gallery focus, co-25 road focus lamps	lighting improved.
tbs-4 on co-21	both boom pile focus lamps installed
tbs-4 on co-21	both boom pile focus lamps installed
brc-2 on co-31 , co-64,65	motor and panel side ppm is done
brc-2 on co-31 , co-64,65	motor and panel side ppm is done
tt-3 on co-16	position sensors cable inspection is done, BPC_1 and BPC-2 area proper insulation provided.,
tt-3 on co-16	position sensors cable inspection is done, BPC_1 and BPC-2 area proper insulation provided.,
co-11 to co-3a chute vibrator	replaced motor and trail run is taken.
co-11 to co-3a chute vibrator	replaced motor and trail run is taken.
1-141lc3 battery bank	discharge done. Charger card reset done and charging of bank started.
1-141lc3 battery bank	discharge done. Charger card reset done and charging of bank started.
DE-5 FAN2	dmpr tripped, found terminations damaged, relugging done, v beltrs removed and motor trail run taken, on load trail run to be done
DE-5 FAN2	dmpr tripped, found terminations damaged, relugging done, v beltrs removed and motor trail run taken, on load trail run to be done