



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/05/2026

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-11 BD	MPCB TRIPPED 3 TIMES	RESET	01:05:00	01:35:00	
2	OHP	CO-22	ZSS NOT HEALTHY CABLE CUT	JOINT DONE AND TESTED	00:15:00	00:30:00	
3	OHP	TBS ON CO-21	LT M-1 OLR ACTED	RESET DONE	03:55:00	04:10:00	
4	OHP	CO-26	OLR ACTED	RESET DONE	04:25:00	04:35:00	
5	CHP	CC-52	MPD TRIPPED ON OL	RESET DONE	02:35:00	02:40:00	
6	CHP	CC-51	MPD TRIPPED ON OL	RESET DONE	02:40:00	02:45:00	
7	WT	CP-2	BREAKER TRIPPED AROUND COL. 16	PADS OK ... MADE ON AND TESTED	04:35:00	04:45:00	