



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/09/2026

Shift: B

Incharge(s): Nagendra Midde, Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 34	OLR ACTED	RESET	16:40:00	16:50:00	
2	OHP	CO 26	OLR ACTED	RESET	17:55:00	18:00:00	
3	OHP	BRC ON CO 32	STONE STUCK IN ZSS YARD INTERLOCK CAGE	REMOVED	21:15:00	21:25:00	