



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/10/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 26	LT not working,M3 mpcb was tripped	made on	18:28:00	18:34:00	
2	OHP	TBS on co 7A	reported LT not working,wire opened in selector switch	properly connected in Remote s/s	16:25:00	16:35:00	
3	OHP	BRC on CO 32	LT not working,OT acted	Ot released	17:50:00	18:10:00	
4	OHP	CO 25	OLR acted	reset	19:10:00	19:20:00	
5	OHP	TBs on Co 19	Lt not working,M4 mpcb tripped	reset	19:20:00	19:35:00	
6	IOSA	WOBR(L and T)	mains not getting on,ACB is in off condition	ACB made on	15:00:00	15:15:00	