



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/08/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	TRIPPED ON OLR/7TIMES	RESET DONE	14:55:00 16:30:00 17:00:00 18:20:00 21:10:00	15:05:00 16:40:00 17:10:00 18:30:00 21:20:00	
2	OHP	LC 7,ASO 3	NO POWER/ACBS TRIPPED AT HVMCC4 FOR MLDB AND PDB-OP141LC4	ACB S MADE ON	15:35:00	16:00:00	
3	CHP	CC 28	TRIPPED ON OLR	RESET DONE	17:10:00	17:20:00	
4	CHP	CC 51	MPD TRIPPED ON OLR	RESET DONE/FEEDEING CONV.STOPED	20:25:00	20:35:00	
5	CHP	CC 52	MPD TRIPPED ON OLR	RESET DONE	21:30:00	21:40:00	
6	WT	OP 7	F/R NOT TAKING PLACE/ACB TRIPPED	ACB MADE ON	18:00:00	18:10:00	
7	WT	OP 8	NOT MOVING/PUSHER AT DEAD ZONE	KEPT IN PARKING ZONE	20:30:00	20:45:00	