



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 18/06/2026

Area: CHP

Equipment	Job
CC 12/13 Gallery	GPL point 4 nos lamp fixtures rectified
CC 28,109,28TT	PPM was done
CC 103TT	Power cable jointed
All JH	De watering pumps inspection done
CC 51	6 nos LED fixtures replaced and improved lighting
S 2	Shifted from CC 102 to CC 39
IC 4	CC 37 isolator ON/OFF mechanism rod fabricated and replaced and made it operate
CC 38,126,SCR5	PPM was done