



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/06/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	OLR ACTED (2TIMES)	RESET DONE	01:30:00 02:20:00	01:35:00 02:25:00	
2	OHP	BRC on CO 8A	b/w not running,CP1 acted/mechanical problem	informed mechanical	05:10:00	05:20:00	
3	CHP	CC-131	OLR ACTED (2TIMES)	RESET DONE	00:20:00 03:05:00	00:25:00 03:10:00	
4	CHP	cc 52	MPD acted	reset	01:40:00	01:45:00	
5	IOSA	OLD WOBR	LT not working,OT acted	OT released,PCRD loop given,PCRD in OFF ,m/c @head end area	22:30:00	22:40:00	