



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 02/05/2026

Area: OHP

| Equipment            | Job                                                                                                                                   |
|----------------------|---------------------------------------------------------------------------------------------------------------------------------------|
| Yard LC and OM's     | AC working status, dewatering pump status is checked.                                                                                 |
| wobr 25,26,6a        | bucket wheel motors inspection is done wob-2 on co-25 bw motors belt canopy is provided on tb.. All space heaters inspection is done/ |
| brc-4 on co-8a       | repaired cabin fan is checked and installed at cabin.                                                                                 |
| co-34 brs            | sensors canopy is provided.                                                                                                           |
| wobr-3 on repair bay | limit switched ppm, It motors checking, are done.welding machine problem is rectified.                                                |
| wobr-4 on co-6a      | luff tb's were damaged, replaced them and solenoid terminations done and tested luff operations.                                      |
| AF-8                 | checking is under progress.                                                                                                           |