



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/05/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 24 LT	M4 TRIP	RESET	22:15:00	22:30:00	
2	OHP	BRC ON CO 25 B/C	INTERLOCK ZSS CAGE STUCK	MADE IT FREE	00:15:00	00:30:00	
3	OHP	BRC ON CO 8A LT	DRIVE 1 BREAK PROBLEM	CABLE DISCONNECTED	00:40:00	01:00:00	
4	OHP	WBR ON CO 26 SLEW	DRIVE TRIPPED	RESET	03:30:00	03:45:00	
5	OHP	BRC ON CO 28	CT SELECTOR SWITCH IS IN LOCAL	KEPT IN REMOTE	01:45:00	02:00:00	
6	OHP	TBS ON CO 24 R B/C	OLR ACTED	RESET	05:40:00	05:55:00	
7	OHP	CO 26	OLR ACTED	RESET	22:05:00	05:05:00	4 TIMES
8	OHP	WBR ON CO 26	B/C MPCB TRIPPING IMMEDIATELY	TO BE CHECKED	05:45:00	06:00:00	
9	OHP	SCR 7 ON CC 39	LT DRIVE TRIPPED	RESET	00:35:00	00:45:00	
10	CHP	SCR 1 ON CC 31	SLEW 30 DEGREE LIMIT ACTED	RELEASED	22:30:00	22:40:00	
11	CHP	CC 125	OLR ACTED	RESET	04:30:00	04:35:00	
12	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	02:00:00	04:00:00	2 TIMES
13	CHP	CC 52	OLR ACTED	RESET	01:30:00	04:30:00	2 TIMES