



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/05/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	olr acted	reset	00:00:00	00:05:00	
2	OHP	CO 26	olr acted	reset	04:30:00	04:40:00	
3	OHP	TBS on CO 24	L BC not running,zssc age stucked due to stone/ belt offcentre	cage made free	23:50:00	00:00:00	
4	CHP	cc 54	motor tripped in olr	reset	01:25:00	01:30:00	2 times
5	CHP	cc 51	mpd triped	reset	03:30:00	03:35:00	
6	CHP	CC 131	olr acted	reset	01:10:00	01:15:00	
7	CHP	cc 31	mpd tripped	reset	03:35:00	03:40:00	
8	WT	CT2	not moving,brake problem,one diode damaged	diode replaced,run in brake mode find ok,than kept in normal mode given clearance	01:55:00	02:38:00	
9	WT	OT 3	D2 tripped	reset	01:40:00	01:45:00	3 times