



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/07/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	01:35:00	01:45:00	
2	CHP	SCR 1 ON CC 31 B/C	ZSS CAGE STUCK	BYPASSED IN I/O RACK	23:05:00	23:15:00	CAGE TO BE CHANGED
3	CHP	SCR 2 ON CC 33	B/W DRIVE TRIPPED	RESET	00:40:00	00:50:00	
4	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	02:35:00	02:40:00	
5	CHP	CC 52	FEEDING CONV OLR ACTED	RESET	01:30:00	02:40:00	4 TIMES
6	CHP	CC 201	OLR ACTED	RESET	02:20:00	02:30:00	
7	CHP	CC 201	ZSS CORE PROBLEM	BYPASSED	04:30:00	04:50:00	