



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/06/2026

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO-6A	LT NOT RUNNING OT ACTED	RELEASED	06:40:00 07:15:00	06:50:00 07:30:00	
2	OHP	CO-5A	MECH BRS NOT RESTING	FIXED PROPERLY	06:56:00	07:08:00	
3	OHP	TBS CO-5A	ALL DRIVES NOT WORKING	POWER OFF IN HVMCC .. NO SUPPLY IN SIPROTEC RELAY ... LOOP GIVEN	11:20:00	12:15:00	TO BE CHECKED AFTER RACK
4	OHP	VF-10A	CHUT VIBRATOR MOTOR TRIPPED	RESET DONE	11:30:00	11:35:00	
5	OHP	WBR ON CO-6A	INTERLOCK CAGE STUCK	MADE FREE	13:35:00	13:45:00	
6	CHP	CC-38	MECH BRS FREQUENTLY ACTING	ALIGNMENT PROBLEM ... FIXED PROPERLY	07:40:00	07:50:00	
7	WT	CP-2	BREAKER TRIPPED	MADE ON COL. NO. 77 ..78	08:10:00	08:20:00	