



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/06/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	olr acted	reset	17:30:00	17:40:00	
2	OHP	CO 25	OLR acted	reset	17:40:00	17:45:00	3 times
3	CHP	cc 131	olr acted	reset	19:30:00	19:35:00	
4	CHP	CC 104 R1	LT not working,panel side control off ,control supply fuse blown	control made on,than after 2o minute fuse replaced	19:40:00	20:25:00	
5	CHP	CC 104 R1	LT not working,M2 tripped	reset	21:00:00	21:05:00	
6	CHP	CC 40 SCR7	b/c not running ,stacking 30 degree slew acted	reset	19:45:00	19:50:00	
7	CHP	CC 125	olr acted	reset	19:30:00	19:35:00	