वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 17/10/2026

Shift: B

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	tripped on olr	reset done	18:00:00 18:50:00 20:40:00	18:05:00 18:55:00 20:45:00	
2	OHP	VF 10A	TRIPPED ON OLR /CHUTE TOUCHING TO THE TRAY	RESET DONE/6TIMES	18:15:00	21:00:00	
3	OHP	CO 34	TRIPPED ON OLR	RESET DONE	17:00:00	17:05:00	
4	OHP	TBS ON CO 22	LBC ZSS ACTING/CAGE STUCKUP WITH STONE	CAGE MADE FREE	14:20:00	14:30:00	
5	OHP	BRC ON CO 8A	ACB TRIPPED	ACB MADE ON	14:20:00	14:40:00	
6	OHP	CO 26	TRIPPED ON OLR	RESET DONE	16:50:00	16:55:00	
7	OHP	CO 56	LOCAL /REMOTE BLINKING	EOCR BLINKING/RESET DONE	20:00:00	20:15:00	
8	CHP	CC107	ZSS ACTING/CAGE STUCKUP	ZSS CAGE REPLACED	17:45:00	18:10:00	
9	CHP	SCR 1 ON CC31	LT NOT TAKING PLACE/PCRD TENSION ACTED DUE TO GUIDE CHAIN PROBLEM	INFORMED TO MECH.	20:00:00	20:15:00	
10	CHP	CC 23	TRIPPED ON OLR	RESET DONE	18:20:00	18:30:00	
11	CHP	CC 130	PC ACTED/CABLE JOINT DAMAGED	RE -JOINTED THEN OK	16:10:00	16:25:00	
12	CHP	CC 131	TRIPPED ON OLR	RESET DONE	19:20:00	19:25:00	
13	CHP	CC52	MPD TRIPPED ON OLR	RESET DONE	16:05:00	16:10:00	
14	CHP	CC 54	TRIPPED ON OLR	RESET DONE	20:40:00	20:45:00	