



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 01/08/2026

Area: CHP

Equipment	Job
All TTs	Cable inspection done
CC 13/14	Take up area lighting improved
CC 220,CC 126 gallery	Lighting fault rectification was done and improved lighting
SCR 5,6	Instrumentation sensors maintenance done
CC 222/223	Belt scale unit maintenance was done
CC 50,SCR 1,8	Motor greasing done
CC 47,50,107	PPM was done
CC 52	Control cable damaged portion on cable tray cut and rejoined
CC 52,53,VS3,VF3	PPM was done