RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 24/10/2026

Area: OHP

Equipment	Job
wbr-4 on co-6a	bw solenoid current increased from 500mA to 640mA on mechanical requirement.
vfd data and field safety devices in ohp yard	inspection is done.
io panel of yard machines	inspection is done.
om-16	lighting is improved
af-14 motor	motor is run from af-8 panel in decoupled condition,
co-28,27a,30a,32a,34a,36a,36b ; vf1 to vf10	motor and panel side ppm is done. vf-1 to vf-10 spare motor is shifted to VF level.
sump pumps inspection	lc-6,ocr telecom room, locp2 mcc,om10 ; co-5 ,1a tunnel , lc-7, lc-5,lc-3,1-141lc3,lbds-4 and 5 is done
vf-21 both motors	feed rate is decreased from 80 to 70%
vs-2 removed motor	motor base welding is done.
co-11a h/e hoist	pendant replaced and hoist control checking is under progress.