



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/06/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	olr acted	reset	19:00:00	19:10:00	
2	CHP	cc 51	mpd acted	olr acted	20:50:00	20:55:00	
3	CHP	CC 47	EStop acted	released	15:45:00	15:55:00	
4	CHP	CC 44	mpd tripped	reset	16:40:00	16:45:00	
5	CHP	CC 104 SCR6	LT not working, track jamming	informed operation	16:50:00	17:00:00	
6	CHP	CC 125	mpd tripped	reset	20:20:00	20:25:00	
7	WT	CO 4(B)	Emergency PB stucked	released properly	19:30:00	19:45:00	