वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 11/10/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	olr acted	reset	16:30:00	16:40:00	4 times
2	OHP	brc on co33m	b/w 2 not running,zss problem,loose connection	tightened it	16:35:00	16:55:00	
3	OHP	VF 16 A	mpcb tripped not getting on,cable shorted	cable re jointed and insulation provided	15:45:00	16:20:00	
4	OHP	TBS on CO 21	no power,control mcb tripped	made it on	21:20:00	21:30:00	
5	CHP	CC 58	motor burnt,all phase IR value 0	crmp side drive kept in ckt	14:20:00	16:00:00	
6	CHP	Cm28	no power,fdr tripped in Lc3	made on by kept off cc58	14:20:00	15:00:00	
7	CHP	CC 131	motor tripped	reset	20:05:00	20:10:00	
8	CHP	CC 54	motor tripped in ol	reset	20:45:00	20:50:00	
9	CHP	CC 32	SCR2 b/c not running,30 deg acted	slew done than ok	14:45:00	14:55:00	
10	CHP	CC 28	olr acted	reset	16:15:00	16:25:00	