



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 01/06/2026

Area: WT

Equipment	Job
OP-9 OP-10	SHEET CUTTING FOR WINDOW CLOSING
OP-7 OP-8	REMOVED DRIVES CHECKING GOING ON
EOT ORE	PPM DONE MAIN HOIST CONTACTOR STRIP CHANGED
OP-8	DRIVE-1 CHECKED FOUND FAULTY .. SHIFTED FOR ETL CHECKING
CT-2	BREAK CONTACTOR CHANGED IN DRIVE PANEL