



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/05/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CC 38 ZSS	MODULE PROBLEM	REPLACED	19:25:00	19:40:00	
2	OHP	TBS ON CO 21 RBC	MPCB TRIPPED	RESET	15:25:00	15:45:00	
3	OHP	CO 25	OLR ACTED	RESET	16:05:00 16:50:00	16:15:00 17:00:00	
4	OHP	RSCO 10A CD	OLR ACTED	RESET	16:50:00	17:00:00	
5	OHP	TBS ON CO 5A	PCRD O/T ACTED	RELEASED	17:10:00	17:30:00	
6	OHP	WBR ON CO 25 LUFF	OLR ACTED	RESET	17:55:00	18:10:00	
7	OHP	TT3	OLD JOINT ONE PHASE OPENED	RECONNECTED	18:00:00	19:00:00	
8	CHP	CC 28	OLR ACTED	RESET	19:35:00 20:45:00	19:40:00 20:55:00	
9	CHP	SCR 3 ON CC 37 B/C	OLR ACTED	RESET	20:00:00	20:10:00	
10	CHP	CP 2	POWER TRIP	RESET	19:40:00	19:50:00	