RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 09/11/2026

Area: WT

Equipment	Job
OT 5	Limit switch ' L S -3' rectified
OP 9 and 10	Greasing done to all Motors
CT 1 and 2	Control Desk maintenance done
AFs(ORE)	All motors cleaning and covering with belt pieces