



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 07/05/2026

Area: CHP

Equipment	Job
CC 213 D/E	PJB welded and cable laid
CM 9,CM 15,CM 16	Rooms cleaning done
cc 26,26a,102	Motor greasing done
SCR 7	LT drive DB provided and cable termination done
CC 8, 33,SCR 2, CC 8 TIS	PPM was done
SCR 2	HT cable old joint sleeve provided by DNW
CM 24	IO rack door opening closed
CC 114	Spare motor coupling fixed