



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/05/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	21:30:00	21:40:00	
2	OHP	WBR ON CO 6A SLEW	POTENTIOMETER PROBLEM AND 24V DC CONTROL MCB FAILED	POTENTIOMETER DISCONNECTED AND MCB REPLACED	14:30:00	16:00:00	
3	OHP	TBS ON CO 7A LT	DRIVE TRIPPED	RESET	14:50:00	15:10:00	
4	OHP	CO 16	OLR ACTED	RESET	20:40:00	20:45:00	
5	CHP	SCR 7 ON CC 39 B/C	OLR ACTED	RESET	18:05:00	18:15:00	
6	CHP	RG3	TRIPPED ON TEMPERATURE FAULT	RESET AND INFORMED TO MECH	18:30:00	19:00:00	
7	WT	OP1 TRIPPED	C CLAMP GOT BEND	REPLACED IT	21:00:00	21:30:00	