



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/10/2026

Area: CHP

Equipment	Job
VS 3,VF 3	PPM was done
CC 215,216,222,223	Belt scale maintenance done
Coal complex,CM 18	Rooms cleaning done
All conveyors and yard machines of CHP	Safety switches and field devices status inspection done
CC 39	Burnt motor coupling removed and sent to ERS
CC 32,SCR5,CC216,219,223	PPM was done