



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/06/2026

Area: OHP

Equipment	Job
co-1a pullchord	checked and restored in circuit.
JH o-2 tunnel and h/e area lighting	cable laid for lighting, lighting is improved.
co- 60 level ; co-63 shuttle conveyor levels	lighting inspection is done.
co-28,27a,30a,32a,34a,36a	panel side ppm is done.
vs-1,2,3,4,5 ; vf-14,15,16,17,18,19,20 ; co-49	motor and panel side ppm is done.
eot-2 remote panel	wiring checking is under progress.
co-31,30 mechanical brs	welding job is under progress.
wobr-2 on repair bay	shifted from repair bay to co-25 and trail run is taken.
wobr-3 on co-25	shifted from co-25 to co-29