RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 07/11/2026

Area: OHP

Equipment	Job
cbms-4a on co-2a	conveyor motor is installed and trail run is taken.
tt-3 on co-16	PCRD resistance failed, replaced resistance and trail run is taken.