



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/06/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS 2A	OLR ACTED	RESET	08:55:00	09:10:00	
2	OHP	WBR ON CO 6A LT	M3 TRIP DUE TO BREAK PROBLEM	RESET BREAK ADJUSTED	09:50:00	10:10:00	
3	OHP	BF 1A	ZSS PROBE CABLE GOT CUT	REJOINED	11:15:00	11:25:00	
4	CHP	SCR 3 ON CC 37	B/C OLR ACTED	RESET	08:40:00	08:50:00	
5	CHP	SCR 8 ON CC 112	B/C ZSS CAGE STUCK	MADE IT FREE	10:00:00	10:15:00	