



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/05/2026

Area: WT

Equipment	Job
DE-1 AND DE-2	MOTOR SIDE PPM DONE
MIS	50 NO OF ISOLATERS SHIFTED FROM OP-4 TO OP-8
OT-4	LS-2 STRIKER MODIFIED AND KEPT IN CKT
OP-4	ALL DRIVES CHECKED FOUND OK .. SENSOR CABLE LAID .
OP-1	2 NO OF POWER COLLECTOR PADS CHANGED