



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 15/05/2026

Area: WT

| Equipment       | Job                                                   |
|-----------------|-------------------------------------------------------|
| LC 1 and 2B /T2 | Charged H T and LT side after D N W clearence         |
| OT 4            | proximate sensor replaced for intial indication       |
| OP 4            | Panel and Motor side ppm including core cleaning done |
| MIS             | Material shifted to op 5                              |