



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/06/2026

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-8	BRS ACTED	SENSORS CLEANED AND RESET	23:30:00	23:40:00	
2	OHP	CO-25	TRIPPED ON OLR	RESET DONE	23:45:00	23:55:00	
3	CHP	CC-112 SCR-8	BC NOT RUNNING	OVER LOAD ON BC .. MOTOR RUNNING INFORMED OPERATION	23:55:00	00:05:00	
4	CHP	CC-29	STOPPING ON ZSS	ZSS CAGE STUCK ... MADE FREE	02:30:00	02:40:00	
5	CHP	CC-51	MPD TRIP	RESET DONE 2 TIMES	01:15:00	02:22:00	
6	CHP	CC-52	MPD TRIPPED 3 TIMES	RESET DONE	01:20:00	02:50:00	
7	WT	OT-3	D2 DRIVE	DRIVE CHANGED .. MOTOR ALIGNMENT DONE .. AUTO TUNING DONE AND TESTED	22:00:00	03:00:00	
8	WT	OP-2	D3 TRIPPED ON OLR	RESET DONE	04:40:00	05:00:00	