



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/06/2026

Area: OHP

Equipment	Job
co-65,66,67 H/E ,T/E and gallery, 62,63 shuttle level,	Lighting is improved.
co-65,66,67 H/E ,T/E and gallery, 62,63 shuttle level,	Lighting is improved.
CR-1A,CR-2A	Both motors greasing at both ends is done.
CR-1A,CR-2A	Both motors greasing at both ends is done.
CR-3A motor Bearing End cover	End cover got damaged at NDE side, removed motor and shifted to CME,
CR-3A motor Bearing End cover	End cover got damaged at NDE side, removed motor and shifted to CME,
wobr-2 on co-29	LT drive restored in VFD and checked LT operation,
wobr-2 on co-29	LT drive restored in VFD and checked LT operation,
LC-8,LC-6,om-16,12,hvmcc-1	RIO bypass checked and list prepared.
LC-8,LC-6,om-16,12,hvmcc-1	RIO bypass checked and list prepared.
co-5a T/E, co-22 T/E , co-29 Yard focus lamps	Lighting is rectified and restored.,
co-5a T/E, co-22 T/E , co-29 Yard focus lamps	Lighting is rectified and restored.,
brc-5 on co-32	MCC and CJB-1 Blowing is done.
brc-5 on co-32	MCC and CJB-1 Blowing is done.
Wobr-3 on co-25	PCRD limit checked, limit arm got free and was not stopping after acting, welded a piece to stop over traveling. and restored in circuit.
Wobr-3 on co-25	PCRD limit checked, limit arm got free and was not stopping after acting, welded a piece to stop over traveling. and restored in circuit.
TT-3 AND CO-16 ; co-15,tt-2,17,76R	motor and panel side PPM DONE



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/06/2026

Area: OHP

Equipment	Job
TT-3 AND CO-16 ; co-15,tt-2,17,76R	motor and panel side PPM DONE
TT-3	CABLE CHECKING DONE AND middle changeover area drum extra loop provided, and its behavior with TT LT is checked.
TT-3	CABLE CHECKING DONE AND middle changeover area drum extra loop provided, and its behavior with TT LT is checked.