



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/06/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	15:30:00	21:00:00	3 TIMES
2	OHP	BRC ON CO 32	B/C EMERGENCY STOP ACTED	RELEASED	21:30:00	21:40:00	
3	CHP	CO 26A	OLR MALFUNCTIONING	REPLACED	15:00:00	16:00:00	
4	CHP	S 3 ON CC 111	B/C OLR ACTED	RESET	14:45:00	14:55:00	
5	CHP	S 3 ON CC 111	B/C SLEW 30 DEGREE LIMIT ACTED	RESET	18:45:00	18:55:00	
6	CHP	CC 131	OLR ACTED	RESET	15:00:00	21:00:00	2 TIMES