# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL GENERAL SHIFT REPORT

Date: 10/10/2026

Area: CHP

| Equipment | Job |
|---|---|
| CC 28 TT | Cable rectification job done |
| CC 215/216 T/E | Extra pump provided and de watered |
| CCR Top | 2 nos 200W LED fixtures replaced |
| CC 47,50,106,SCR 8 | PPM was done |
| CC 51 | MCCB module bus bar side single finger contacts replaced with double finger contacts |
| LC 19(CM 23) | Bus bar maintenance was done |