



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/08/2026

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-34 BRC	LT DRIVE TRIPPED	RESET DONE	10:30:00	10:45:00	
2	CHP	CC-54	TRIPPED ON OLR 3 TIMES	RESET DONE	08:35:00	08:55:00	
3	CHP	CC-51	MPD ACTED	RESET DONE	09:15:00	09:20:00	
4	CHP	CC-28	TRIPPED ON OLR	RESET DONE	10:00:00	10:10:00	
5	CHP	CC-29	POSITION BIT MISSING ON CC-31	BYPASSED IN IO RACK	10:50:00	11:00:00	
6	CHP	PROCESOR B	COMMUNICATION PROBLEM (2 TIMES)	PROCESSOR POWER RECYCLE , PROGRAM RELOADING , WARM RESTART	07:30:00	12:45:00	
7	WT	OT-3	D1 TRIPPED ON ENCODER FAULT	RESET DONE	08:45:00	08:50:00	
8	WT	OP-3	D3 B PHASE LUG DAMAGED	REPLACED	12:00:00	12:15:00	