



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	olr acted	reset	14:00:00	14:10:00	3 times
2	OHP	TBS on CO 5A	LT not working,pcrd OT acted	OT released	16:40:00	17:00:00	
3	OHP	BRC on CO 28	b/w 2 not moving,back plate stucked in bucket	informed mechanical and operation	17:00:00	17:15:00	
4	OHP	CO 35	olr acted	reset	20:50:00	21:00:00	