वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 10/11/2026

Shift: A

Incharge(s): Lal Singh

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | ALL OHP | NO POWER IN RMHP FROM LBSS-1 | TESTED AFTER POWER RESTORATION | 09:45:00 | 10:25:00 | |
| 2 | OHP | CO-26 | TRIPPED ON OLR 3 TIMES | RESET DONE | 08:15:00 | 11:55:00 | |
| 3 | OHP | CO-19 TBS | LEFT LUFF NOT WORKING | OLR ACTED RESET DONE | 08:20:00 | 08:30:00 | |
| 4 | OHP | BRC ON CO-28 AND CO31 | NO POWER ... ACB TRIPP DUE TO POWER FAIL | MADE ON | 11:00:00 | 11:20:00 | |
| 5 | OHP | WF-5 | STOPPING ON ZSS | LOOP LOOSE .. FIXED PROPERLY | 11:45:00 | 11:55:00 | |
| 6 | OHP | VF-10A | TRIPPED | RESET | 12:20:00 | 12:30:00 | |
| 7 | OHP | CO-48 | TRIPPED ON OLR | RESET DONE | 13:00:00 | 13:05:00 | |
| 8 | CHP | ALL CHP | NO POWER | TESTED AFTER POWER RESTORATION FROM LBSS | 09:45:00 | 10:20:00 | |
| 9 | CHP | SCR-9 ON CC104 | PCRD TENSION ACTED | RELEASED AND TESTED | 07:40:00 | 07:50:00 | |
| 10 | CHP | SCR-5 CC-32 | LT DRIVE TRIPPED | RESET DONE | 08:00:00 | 08:15:00 | |
| 11 | CHP | SCR-5 CC-32 | BC MCCB TRIP | CHECKED MADE ON AND TESTED | 08:50:00 | 09:05:00 | |
| 12 | CHP | CC-35 S-2 | SLEW NOT WORKING ... SLEW 30 DEGREE LIMIT ACTED | RELEASED AND TESTED | 11:45:00 | 11:55:00 | |
| 13 | CHP | CC-201 TO CC 215 | ALL RED ....UPS SUPPLY PROBLEM | MADE ON AND TESTED | 12:30:00 | 13:05:00 | |
| 14 | CHP | CC-18 | ZSS CAGE STUCK | MADE FREE | 12:00:00 | 12:10:00 | |

वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 10/11/2026 Shift: A

Incharge(s): Lal Singh

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 15 | CHP | CC-28 | POSTION SENSOR DAMAGED | BYPASSED IN IO RACK | 08:30:00 | 08:40:00 | |
| 16 | CHP | CC-14 | TRIPPED ON OLR | RESET DONE | 12:30:00 | 12:40:00 | |
| 17 | CHP | CC-131 | TRIPPED ON OLR | RESET DONE | 12:45:00 | 12:50:00 | |
| 18 | WT | OP-6 | NOT MOVING ...D-5 ROTOR CONTACTOR STUCK | MADE FREE | 08:15:00 | 08:30:00 | |