



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/07/2026

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 7	BRS ACTED/JOD	RESET DONE	11:45:00	12:00:00	
2	OHP	CO 3A	PC ACTED/CABLE CUT DUE TO BABCAT WORKING TO CLEAR THE SPILLAGE MATERIAL	BYPASSED AT CJB	12:35:00	12:50:00	KEPT IN CKT 12.45PM
3	OHP	CO 26	TRIPPED ON OLR	RESET DONE	07:30:00	07:40:00	
4	OHP	CO 33M	TRIPPED ON OLR	RESET DONE	07:55:00	08:00:00	
5	OHP	CO 58	ZSS ACTED/CAGE STUCKUP WITH STONE	CCAGE MADE FREE	11:00:00	11:15:00	
6	OHP	CC 201	TRIPPED ON OLR	RESET DONE	08:40:00	08:50:00	
7	OHP	CO 59	ZSS ACTED/CAGE STUCKUP	CAGE MADE FREE	13:30:00	13:45:00	
8	CHP	CC 51	MPD TRIPPED NO OLR	RESET DONE/2TIMES	09:00:00	09:30:00	
9	CHP	CC 131	TRIPPED ON OLR	RESET DONE	10:00:00	10:10:00	
10	CHP	CC 58	TRIPPED ON OLR	RESET DONE	11:35:00	11:40:00	
11	CHP	SCR 3 ON CC37	BC NOT RUNNING/MPR TRIPPED ON SP FAULT	DIDNT FOUND ANY PROBLEM /RESET DONE	11:05:00	11:15:00	
12	CHP	SCR 3 ON CC37	BC NOT RUNNING/OLR ACTED	RESET DONE	12:00:00	12:10:00	
13	WT	OP 3	F/R NOT TAKING PLACE /M1 POWER CABLE GOT DAMAGED	/ RE JOINT DONE THEN OK	09:15:00	09:30:00	