# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL GENERAL SHIFT REPORT

Date: 07/11/2026

Area: OHP

| Equipment | Job |
|---|---|
| cbms-4a on co-2a | conveyor motor is installed and trail run is taken. |
| tt-3 on co-16 | PCRD resistance failed, replaced resistance and trail run is taken. |