



वी.एस.पी  
VSP

RASHTRIYA ISPAT NIGAM LIMITED  
VISAKHAPATNAM STEEL PLANT  
RAW MATERIAL HANDLING PLANT  
ELECTRICAL GENERAL SHIFT REPORT

Date: 18/05/2026

Area: OHP

| Equipment                                         | Job                                                                                         |
|---------------------------------------------------|---------------------------------------------------------------------------------------------|
| co-36,48,49, h/e hoists ; and bombay crane hoist. | ppm is done.                                                                                |
| co-36,37,47,48,49                                 | motor and panel side ppm is done.                                                           |
| lc-6 earth pits                                   | testing and inspection of earth pits is done.                                               |
| co-17,18                                          | field safety devices ppm is done.                                                           |
| co-5,17                                           | motor and panel side ppm is done.                                                           |
| om-12,16, LC-8                                    | housekeeping is done.                                                                       |
| hvmcc-1 spare motors                              | all motors checked and found ok.                                                            |
| tis on co-29                                      | checked along with mechanical and kept in circuit.                                          |
| cbms of co-6a                                     | provision for magnet lowering is checked and planned.                                       |
| wobr-4 on co-6a luff limits                       | checking is done and found working and in circuit.                                          |
| repair bay ht transformer                         | tank support welding job is under progress                                                  |
| tbs-1 on co-22 ; tbs-2 on co-20                   | mcc panels blowing is done.                                                                 |
| jh o-14,15,                                       | cctv supply boards fixing purpose support welding is done. supply provided at jh o-14 area. |