वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 12/10/2026

Shift: A

Incharge(s): Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC-32	LT NOT RUNNING	WRONG COMPLAINT	11:50:00	12:05:00	
2	OHP	BRC ON CO-8A	LT NOT WORKING PCRD NOT HEALTHY	PCRD MPCB ADD-ON BLOCK PROBLEM ... BYPASSED	09:45:00	10:40:00	TO BE REPLACED AND KEPT IN CKT
3	CHP	CC-37 SCR-3	LT NOT TAKING PLACE	DRIVE TRIPPED ... RESET DONE	07:00:00	07:10:00	
4	CHP	CC-37 SCR-3	BC NOT RUNNING MPR TRIPPED	RESET DONE	08:20:00	08:30:00	
5	CHP	CC-32	MPD TRIPPED	RESET DONE	11:15:00	11:25:00	