



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/08/2026

Incharge(s): P Venkat Kiran,P Venkat Kiran

Shift: A

| Sl No | Area | Equipment      | Problem                               | Action                            | From     | To       | Remarks |
|-------|------|----------------|---------------------------------------|-----------------------------------|----------|----------|---------|
| 1     | OHP  | tbs-3 on co-5a | LT not taking place                   | PCRD over tension acted. released | 10:10:00 | 10:20:00 |         |
| 2     | OHP  | co-33m         | OLR acted                             | reset done                        | 08:15:00 | 08:20:00 |         |
| 3     | CHP  | cc-131         | TRIPPED ON OLR                        | RESET DONE                        | 12:40:00 | 12:45:00 |         |
| 4     | CHP  | CC-33 SCR-2    | LT NOT WORKING PCRD DRUM SENSOR ACTED | RESET DONE                        | 11:45:00 | 12:00:00 |         |