



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/08/2026

Incharge(s): Nagendra Midde,K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 32 B/W	OIL level Low	Informed to mech	15:20:00	15:35:00	
2	OHP	CO 26	OLR acted	Reset	18:55:00	19:05:00	
3	OHP	CO 11A	Motor Fan Finns got damaged and Fan cover Fell down	Fan cover Properly placed and Pedestal fan is provided	19:30:00	20:00:00	
4	CHP	CC 130	Motor coupled	Trail Run taken	18:00:00	20:15:00	
5	CHP	Scr 7 On CC 40	B/C Olr acted	Reset	20:30:00	20:45:00	
6	CHP	CC 51	Feeding conv Olr acted	Reset	17:35:00	17:40:00	
7	IOSA	OC 27 A	Healthy Stop Due to PC acting momentarily	Bypassed	20:20:00	21:00:00	
8	IOSA	L and T WBR B/W	Suction Valve LS1 acted	Released	17:00:00	17:30:00	
9	IOSA	L and T WBR LT	Rev End limit Acted	Released	17:00:00	17:15:00	