



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/08/2026

Incharge(s): Saurabh Kumar Yadav, G Eswara Rao

Shift: C

| Sl No | Area | Equipment     | Problem                                        | Action               | From     | To       | Remarks |
|-------|------|---------------|------------------------------------------------|----------------------|----------|----------|---------|
| 1     | OHP  | co 25         | olr acted                                      | reset                | 23:05:00 | 23:15:00 | 3 times |
| 2     | OHP  | co 26         | olr acted                                      | reset                | 04:20:00 | 04:30:00 |         |
| 3     | CHP  | CC 40         | TRIPPED ON OLR440                              | RESET DONE           | 04:40:00 | 04:50:00 |         |
| 4     | CHP  | WOBR ON CO 29 | BC NOT running, found belt is slipping         | informed mechanical  | 03:25:00 | 03:35:00 |         |
| 5     | CHP  | cc 52         | mpd acted                                      | reset                | 04:45:00 | 04:50:00 |         |
| 6     | CHP  | cc 54         | olr acted                                      | reset                | 05:15:00 | 05:20:00 |         |
| 7     | WT   | OP 10         | F/R NOT TAKING PLACE/DID" NT FOUND ANY PROBLEM | RESET DONE IN SYSTEM | 22:50:00 | 23:00:00 |         |